

Fire & Emergency Lighting Test Sheet



Date 01/02/2022

Job 1 Timberdene

Device No.	Device Type	Device Location	Pass	Fail
	Smoke Detector	Ground Floor Entrance	✓	
	Call Point	Ground Floor Entrance	✓	
	Smoke Detector	Lounge	✓	
	Smoke Detector	Room 1	✓	
	Smoke Detector	Room 2	✓	
	Smoke Detector	Room 3	✓	
	Smoke Detector	Room 4	✓	
	Smoke Detector	Room 5	✓	
	Smoke Detector	Room 6	✓	
	Call Point	Kitchen	✓	
	Smoke Detector	Kitchen	✓	
	Smoke Detector	Landing	✓	

Sounder Test (Tick)
✓

Battery Test (Tick)
N/A

Battery Size
2.1ah

Battery Date
Jan-19

Em Light No.	Emergency Light Location	Pass	Fail
	Ground Floor Entrance	✓	
	Lounge Area	N/A	
	Stairwell	✓	
	Kitchen	✓	
	Landing	✓	

Name JEFF HAZELL

Signature

Notes